

PMA AG | Aathalstrasse 90
Headquarters | CH-8610 Uster | Switzerland

Tel. +41 44 905 61 11
Fax +41 44 905 61 22
info@pma.ch
www.pma.ch



To whom it may concern

our ref. | Ihre Referenz

our ref. | Unsere Referenz
SH

date | Datum
07.03.2013

Suitability of ATEX certified PMA conduits and fittings for ESD sensitive environments

Ladies and Gentlemen

We would like to confirm herewith that the surface resistance of our ATEX certified conduits and fittings has been duly tested according to the provisions of IEC 60079 and found to be <math><1G\Omega</math> at 500V DC.

This value lies within the limits defined for static dissipative materials and is therefore safe for use in ESD sensitive environments.

With kind regards

PMA AG



Peter Schuster
Technical Director

Zürcher Kantonalbank | Konto 730 1130-0035.533 CHF
CH-8610 Uster | IBAN CH05 0070 0113 0000 3553 3
Konto 755 1355-00004.413 EUR
IBAN CH37 0070 0135 5000 0441 3
SWIFT ZKBK CH 77 80A

Credit Suisse | Konto 5288 477072-31 CHF
CH-8610 Uster | IBAN CH28 0528 8047 7072 3100 0
Konto 5288 477072-32-2 EUR
IBAN CH37 0528 8047 7072 3200 2
SWIFT CRES CH ZZ 80A

PC-Konto 80-13872-9
MwSt.-Nr. 221 355
ZAZ-Konto 1750-6