



System pull-out strength

(DO 9.21-4610, IEC EN 61386)

This standard defines the system pull-out test on conduits and connectors under standard ambient conditions (23°C/50% relative humidity). The conduits are mounted with the appropriate system connectors. The pull-out strength of the system is determined in a tensile test.